



Notes:
 1. Coax cables shown connecting from face 1 to face 2 to face 3 to face 4 supplied by Nevco.
 2. Power cables for each face supplied by Nevco
 3. This sign is intended to be installed in accordance with the requirements of Article 600 of the National Electric Code and/or other applicable local codes. This includes proper grounding and bonding of the sign.

Total 4-Face Board Power

Model	Amps (120VAC)				Amps (240VAC)			
	-NL	-RL	-ETN-NL	-ETN-RL	-NL	-RL	-ETN-NL	-ETN-RL
2700/2702	3.3	3.6	4.2	N/A	1.7	1.8	2.1	N/A
2710/2712	4.0	4.5	4.8	5.1	2.0	2.2	2.4	2.5
2750	4.0	4.7	4.7	5.3	2.0	2.3	2.4	2.6
2770/2772	4.1	5.0	4.9	5.6	2.0	2.5	2.5	2.8
4710	4.64	5.16	5.5	5.8	2.3	2.6	2.75	2.9
4711	5.48	6.12	6.3	6.7	2.75	3.05	3.15	3.35
4750	5.08	5.76	5.9	6.4	2.55	2.9	2.95	3.2
4770	3.36	4.04	4.6	4.24	1.68	2.02	2.3	2.12
2780			4.6				2.3	
2781			4.9				2.48	
2785			5.9				2.9	

4-Face Wired Installation		
	Nevco, Inc. Greenville, Illinois 62246	
Last ECO	Drawing No. 275-0157	
Drawn DLP	Date 5/3/2018	Sheet 1 of 1